ELECTRICAL WARNINGS

A WARNING ELECTRICAL SHOCK HAZARD

Disconnect power before installing or servicing this product. A qualified service person must install and service this product according to applicable electrical and plumbing codes.

RNING EXPLOSION OR FIRE HAZARD



Do not use this product with flammable liquids. Do not install in hazardous locations as defined by National Electrical Code, ANSI/NFPA 70.


Failure to follow these precautions could result in serious injury or death. Replace product immediately if switch or cable becomes damaged or cracked. Keep these instructions with warranty after installation. This product must be installed in accordance with National Electric Code, ANSI/NFPA 70 so as to prevent moisture from entering or accumulating within boxes, conduit bodies, fittings, float housing, or cable.


For detailed specifications on this product, or for the complete line of CSI Controls[®] panel, alarm, and switch products, visit our website at www.csicontrols.com.

A Pump Switch is designed for Horsepower (HP) rated loads and is not suitable for control (pilot duty) applications. It will fail prematurely when switching loads less than 1 Amp at 120 VAC. Select a float switch from our Control Switch offering for control applications.

MEDIUM DUTY LIMITED SPACE Pump Switch

Installation Instructions





MEDIUM DUTY LIMITED SPACE PUMP SWITCH 🕑

This mechanically activated pump switch is designed for direct control of pumps in non-potable water and sewage applications. It works well in applications with limited space such as: small sump chambers, effluent applications, and laundry trays, as well as in large tanks.

The Medium Duty Limited Space pump switch is not sensitive to turbulence.

It is available for pump down applications only.

CSI CONTROLS® FIVE-YEAR LIMITED WARRANTY

Five-Year Limited Warranty. For complete terms and conditions, please visit **www.csicontrols.com**.

CSI Controls.

Technical Support: +1 800-746-6287 techsupport@sjeinc.com www.csicontrols.com

Technical Support Hours: Monday - Friday, 7 A.M. to 6 P.M. Central Time

PREVENTATIVE MAINTENANCE

- Periodically inspect the product. Check that the cable has not become worn
 or that the housing has not been damaged so as to impair the protection
 of the product. Replace the product immediately if any damage is found or
 suspected.
- Periodically check to see that the float and rod are free to move and operate the switch.
- Use only CSI Controls® replacement parts.

PN 1023632C 05/22 © 2020 SJE, Inc. All Rights Reserved. CSI CONTROLS is a trademark <u>of SJE. Inc.</u>

NOTICE!

Products returned must be cleaned, sanitized, or decontaminated as necessary prior to shipment to ensure that employees will not be exposed to health hazards in handling said material. All applicable laws and regulations shall apply.

